



903 NW 35th Street
Boca Raton, FL 33431
561-391-2202
BocaAirport.com

2020-BRAA-002-AIRPORT ROAD MONUMENT SIGNS Addendum #2

Questions received to date are as follows:

1. Is there already electric at the sign site for the pole lights?
There is existing electrical pull box within 10' of the proposed monument sign location to facilitate the electrical connection to the sign. The Contractor will be required to extend the existing 20A, 120V circuit conductors (2#10, 1#10G) located within an electrical pull box to the proposed sign and make all connections necessary for a complete working system in place."
2. Does the bid include landscaping removal and installation?
Proposal should include any removal necessary to facilitate the installation of the sign.