
ADDENDUM NO. 3
TO THE CONSTRUCTION DOCUMENTS
FOR THE
AIR TRAFFIC CONTROL TOWER RADIO, COMMUNICATION AND
ELECTRONIC UPGRADES
BOCA RATON AIRPORT

Project funded by:

FLORIDA DEPARTMENT OF TRANSPORTATION (FDOT)

August 3, 2022

PAGE 1 of 2

TO: ALL HOLDERS OF CONTRACT DOCUMENTS

- a. Your attention is directed to the following interpretations of, changes in, and additions to the Contract Specifications and Plans for the above named project at Boca Raton Airport, Boca Raton, Florida.
- b. This Addendum is part of the Contract Documents and Plans, and the bidders are required to acknowledge receipt of this Addendum in the space provided below.

This addendum includes the following (see attachments):

- 1. **CONTRACTOR RFI'S**
(Responses to Bidders Questions)

NOTE: **Sign and Return Addendum #2 Cover with Bids**

Acknowledged: _____ signature of Bidder

Name of Bidder: _____ Date: _____

END OF ADDENDUM NO. 3

CONTRACTOR QUESTIONS/CLARIFICATIONS

- 1. We have significant experience installing communications and other equipment in new and existing ATC facilities and can provide references to support this claim. Although we have worked with and installed the manufacturer's equipment we will propose for this project, we do not have formal "letters of approval" from the manufacturers signifying us a "manufacturer certified installer". Is this requirement necessary and, if so, is it disqualifying?**

A: A statement on Company letterhead from the equipment manufacturer indicating that the installing company is an authorized installer of the manufacturer's equipment and that the manufacturer shall fully warranty the installed equipment shall be acceptable in lieu of a "manufacturer certified installer".

- 2. Does a Florida State licensed low voltage cable installer meet the requirement for a "certified cable installer" in the RFP? The RFP refers to Building Industry Consulting Service International (BICSI) certifications that our staff doesn't have and BICSI certified subcontractors are difficult to find.**

A: Yes, a Florida State licensed low voltage cable installer shall meet the requirement for a "certified cable installer".

- 3. The solicitation requires a BICSI certified Registered Communications Distribution Designer (RCDD) be on staff and onsite during the installation. As stated above, we have installed many ATC communications systems and have not previously had this requirement. What is the purpose of this requirement? We are having some difficulty meeting this requirement. Can it be waived??**

A: Yes, the requirement for a BICSI-certified Registered Communications Distribution Designer (RCDD) shall be waived.

- 4. The bid docs mentioned replacing the ATIS interface but in another location in the docs it only mentions the recorder.**

A: Replacement of the ATIS system shall be complete.

- 5. Does the Owner want to go with a voice-operated voice recorder unit like is there now or a keyboard computer interfaced unit that is available?**

A: Provide a voice-operated voice recorder.

- 6. Will the RFI period be extended with the bid period extension?**

A: Yes, the RFI period closes on August 11th at 2:00pm.